

CERTIFICATE



HYGIENIC QUALIFICATION OF AIR PURIFICATION DEVICE ‚Blue.care⁺ M‘ BASED ON VDI 6022-1:2018-01

CONTRACTEE	Hengst SE
INSPECTED OBJECT	Air purification device model Blue.care ⁺ M
INSPECTED SCOPE	Evaluation of the hygienic safety and usability in medically used rooms without particular hygienic requirements (e.g. room class II) and conformity based on VDI 6022-1: 2018-01.
INSPECTION REPORT	37672-LR-GUT-BCM-0221-B
INSPECTION RESULT	The hygienic harmlessness and conformity of the air purification device Blue.care ⁺ M (with a HEPA filter according to DIN EN 1822-1:2019-10) based on VDI 6022-1:2018-01 is confirmed. A particulate and microbiological reduction in the room air has been demonstrated through the use of the air cleaning device.
DATE OF ISSUE	2021-04-12
AUTHORISATION	Dr. Frank Wille, Münster



Dr. Frank Wille