

CERTIFICATE



HYGIENIC QUALIFICATION OF AIR PURIFICATION DEVICE ‚Blue.care+‘ BASED ON VDI 6022-1:2018-01

| | |
|-------------------|--|
| CONTRACTEE | Hengst SE |
| INSPECTED OBJECT | Air purification device model Blue.care+ |
| INSPECTED SCOPE | Evaluation of the hygienic safety and usability in medically used rooms without particular hygienic requirements (e.g. room class II) and conformity based on VDI 6022-1: 2018-01. |
| INSPECTION REPORT | 37672-GUT-LR-0121-B |
| INSPECTION RESULT | The hygienic harmlessness and conformity of the air purification device Blue.care+ (with a HEPA filter according to DIN EN 1822-1:2019-10) based on VDI 6022-1:2018-01 is confirmed. A particulate and microbiological reduction in the room air has been demonstrated through the use of the air cleaning device. |
| DATE OF ISSUE | 2021-04-12 |
| AUTHORISATION | Dr. Frank Wille, Münster |



Dr. Frank Wille